

Organisation Name	Scheme Code	Scheme Name	Supply Type	Source Type	Population Served	Volume Supplied	Derogation For Supply	Type Of Treatment
Mayo County Council	2200PUB1001	ACHILL RWSS	PWS	SU	2556	1652	No	Coagulation using soda ash, kibble alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using
Mayo County Council	2200PUB1004	Ballina - Lisglennon	PWS	SU	5379	3482	No	Coagulation using liquid alum and Allfloc B515PWG polyelectrolyte, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Fluoridation also
Mayo County Council	2200PUB1003	Ballina - Wherrew	PWS	SU	3044	2219	No	Coagulation using liquid alum and Allfloc B515PWG polyelectrolyte, Upward flow Clarifier, rapid gravity filtration followed by disinfection using chlorine gas. Fluoridation also
Mayo County Council	2200PUB1008	Ballina Town Mixed Supply	PWS	SU	11100	4620	No	Coagulation using liquid alum and Allfloc B515PWG polyelectrolyte, clarification by settlement, rapid gravity filtration followed by disinfection using chlorine gas. Fluoridation also
Mayo County Council	2200PUB1005	Ballycastle PWS	PWS	SP	402	168	No	Chlorination using liquid chlorine.
Mayo County Council	2200PUB1037	Ceide Fields PWS	PWS	SP	0	26		Chlorination
Mayo County Council	2200PUB1010	Charlestown PWS	PWS	SP	1104	549	No	Chlorination using liquid chlorine.
Mayo County Council	2200PUB1030	Clare Island PWS	PWS	SU	182	109	No	Slow Sand Filtration and OSEC Chlorination
Mayo County Council	2200PUB1013	Crossmolina PWS	PWS	SP	1538	928	No	Chlorination using sodium hypochlorite.
Mayo County Council	2200PUB1007	ERRIS RWSS	PWS	SU	4154	3504	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Upward flow Clarification, Rapid gravity filtration and chlorination using chlorine gas. Fluoridation also
Mayo County Council	2200PUB1014	Foxford PWS	PWS	SU	1653	553	No	PACL dosing, Multiflow Clarification followed by Slow sand filtration and chlorination using sodium hypochlorite
Mayo County Council	2200PUB1031	Inishturk PWS	PWS	SU	34	28	No	Slow sand filtration and chlorination OSEC
Mayo County Council	2200PUB1015	Kilnelly PWS	PWS	GR	1085	668	No	Chlorination using sodium hypochlorite and UV.
Mayo County Council	2200PUB1017	Kiltimagh PWS	PWS	SU	1640	703	No	Coagulation using polyaluminium chloride and poly Clearfloc 501P. Upward flow Clarifier and RGSF. Chlorination using chlorine gas. Fluoridation.
Mayo County Council	2200PUB1036	KNOCK AIRPORT	PWS	SP	2	56	No	Chlorination using sodium hypochlorite.
Mayo County Council	2200PUB1032	LOUGH MASK RWSS	PWS	SU	39435	31126	No	Coagulation using ferric sulphate and poly LT27, clarification by settlement, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PUB1039	Lough Mask Westport Town	PWS	SU	3969	1889	No	see Westport WTP & Lough Mask
Mayo County Council	2200PUB1020	Louisburgh PWS	PWS	SU	878	296	No	Coagulation using Soda Ash, PAC and poly LT225, Dissolved Air Flotation/Filtration (DAFF) followed by disinfection using chlorine gas. pH correction using soda ash. Fluoridation also
Mayo County Council	2200PUB1021	Muiranny PWS	PWS	SU	710	391	No	Coagulation using soda ash, kibble alum, Clarification by settlement, rapid gravity filtration and chlorination using sodium hypochlorite.
Mayo County Council	2200PUB1022	Newport PWS	PWS	SU	684	277	No	Coagulation using soda ash and Kibbled Alum, Clarification by settlement, rapid gravity filtration and chlorination using Sodium Hypochlorite.
Mayo County Council	2200PUB1024	Swinford PWS	PWS	SU	1820	630	No	Coagulation using poly aluminium chloride and Allfloc B515PWG polyelectrolyte, clarification (DAFF) filtration followed by disinfection using chlorine gas. Fluoridation also
Mayo County Council	2200PUB1025	Westport PWS	PWS	SU	3297	1698	No	Coagulation using Soda Ash, PAC and poly LT255, Upward flow Clarifier, rapid gravity filtration followed by disinfection using chlorine gas. Ph adjustment using soda ash. Fluoridation also
Mayo County Council	2200PRI12164	ABBEYQUARTER pGWS	PUG	SU	104	18	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI12195	ARDS/CURRANE pGWS	PUG	SU	26	0	No	Coagulation using kibble alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI12211	BALLINLOUGH pGWS	PUG	SU	114	24	No	Coagulation using polyaluminium chloride and poly Clearfloc 903P, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Ph adjustment using soda ash. Fluoridation also
Mayo County Council	2200PRI2366	BALLYFARNAGH/MAGHUI PWS	PUG	SU	72	15	No	Coagulation using ferric sulphate and poly LT 27, clarification, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2274	BALLYHOLAN pGWS	PUG	SU	84	20	No	Coagulation using liquid alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2358	BALLYSAKERRY pGWS	PUG	SU	87	29	No	Coagulation using liquid alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2012	BEKAN & DISTRICT pGWS	PUG	SU	504	250	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2013	BELCARRA pGWS	PUG	SU	1149	311	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2383	BRACKLON/BOHEA pGWS	PUG	SU	60	187	No	Coagulation using polyaluminium chloride and poly Clearfloc 903P, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Ph adjustment using soda ash. Fluoridation also
Mayo County Council	2200PRI2251	CAHIR pGWS	PUG	SU	62	0	No	connected to the LOUISBURGH PWS
Mayo County Council	2200PRI2262	CARNE pGWS	PUG	SU	125	27	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2439	Carranaradh PWS	PUG	SU	104	12	No	PACL dosing, Multiflow Clarification followed by Slow sand filtration and chlorination using sodium hypochlorite. (Sodium Hypochlorite 10/12% no softener) Please refer to the site for further details.
Mayo County Council	2200PRI2357	CARRAS DISTRICT pGWS	PUG	SU	879	222	No	Coagulation using ferric sulphate and poly LT 27, clarification, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI12214	CLOGHER (WESTPORT) PWS	PUG	SU	301	62	No	Coagulation using polyaluminium chloride and poly Clearfloc 903P, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Ph adjustment using soda ash. Fluoridation also
Mayo County Council	2200PRI2253	CLOONGEE pGWS	PUG	SU	127	30	No	PACL dosing, Multiflow Clarification followed by Slow sand filtration and chlorination using sodium hypochlorite. (Sodium Hypochlorite 10/12% no softener) Please refer to the site for further details.
Mayo County Council	2200PRI2277	CLOONISLAUN pGWS	PUG	SU	156	40	No	Coagulation using liquid alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2389	CLOONRANE pGWS (GALTS)	PUG	SU	6	10	No	Coagulation using ferric sulphate and poly LT 27, clarification, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2438	COMMINCH pGWS	PUG	SU	55	15	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Fluoridation also
Mayo County Council	2200PRI2034	COOGUE pGWS	PUG	SP	153	136	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2370	CORDARRAGH pGWS	PUG	SU	54	13	No	Coagulation using polyaluminium chloride and poly Lt25S. Chlorination using chlorine gas
Mayo County Council	2200PRI2674	CORTOON (KILTIMAGH) PWS	PUG	SU	50	10		
Mayo County Council	2200PRI2380	CRIMLIN/ROSS pGWS	PUG	SU	255	47	No	Coagulation using ferric sulphate and poly LT 27, clarification, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2292	CRUMPAUN pGWS	PUG	SU	88	22	No	Coagulation using kibble alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2236	DALGAN pGWS	PUG	SU	70	19	No	Coagulation using liquid alum, rapid gravity filtration and chlorination using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2376	DELVIS/KNOCKBRACK pGWS	PUG	SU	177	47	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2375	DERRY pGWS	PUG	SU	84	13	No	Coagulation using ferric sulphate and poly LT 27, clarification, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2284	DERRYNAMEEL/DERRY PWS	PUG	SU	54	17	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2198	DOEGA pGWS	PUG	SU	143	74	No	Coagulation using kibble alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Fluoridation also.
Mayo County Council	2200PRI2154	DOOHOMA/DERRYCORA PWS	PUG	SU	1016	227	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Fluoridation also
Mayo County Council	2200PRI2200	DOONIVER pGWS	PUG	SU	257	51	No	Coagulation using kibble alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Fluoridation also.
Mayo County Council	2200PRI2368	DOYORK pGWS	PUG	SU	207	58	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2399	DRUMMINROE (WEST) PWS	PUG	SU	106	22	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2201	DUGORT (EAST) NO. 1 pGWS	PUG	SU	130	45	No	Coagulation using kibble alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Fluoridation also.
Mayo County Council	2200PRI2199	DUGORT NO. 2 pGWS	PUG	SU	182	40	No	Coagulation using kibble alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Fluoridation also.
Mayo County Council	2200PRI2049	ELLYBLACKSOD pGWS	PUG	SU	850	211	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Fluoridation also
Mayo County Council	2200PRI2501	Emlybeg Common/Carne PWS	PUG	SU	62	0	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Fluoridation also
Mayo County Council	2200PRI2283	FOXPOINT/BARNATRA PWS	PUG	SU	88	13	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2445	GLENCastle pGWS	PUG	SU	101	25	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Fluoridation also
Mayo County Council	2200PRI2381	GORTEEN (SHRILE) pGWS	PUG	SU	78	25	No	Coagulation using liquid alum, rapid gravity filtration and chlorination using chlorine gas. Fluoridation also.
Mayo County Council	2200PRI2060	GURTEEN/CARROWKEE PWS	PUG	SU	478	380	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2327	KEENAGHBEG (KEENAGH) PWS	PUG	SU	200	30	No	None
Mayo County Council	2200PRI2071	KILGARRIFF pGWS	PUG	GR	140	64	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also
Mayo County Council	2200PRI2148	KILKEERAN pGWS	PUG	GR	57	33	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash. Fluoridation also

Organisation Name	Scheme Code	Schema Name	Supply Type	Source Type	Population Served	Volume Supplied	Derogation For Supply	Type Of Treatment
Mayo County Council	2200PRI2224	KILLAWALLA pGWS	PUG	SU	348	90	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash.
Mayo County Council	2200PRI2538	KINLOUGH pGWS	PUG	SU	51	20	No	Coagulation using liquid alum sand filtration and chlorination using sodium hypochlorite and UV. Flouridation also.
Mayo County Council	2200PRI2510	Knockatubber pGWS	PUG	SU	60	0	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash.
Mayo County Council	2200PRI2378	LECARROW (BALLYHAU)	PUG	SU	39	0	No	Coagulation using ferric sulphate and poly LT27, clarification, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using soda ash.
Mayo County Council	2200PRI2082	LISSATAVA pGWS	PUG	SU	195	37	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash.
Mayo County Council	2200PRI2190	MEELICKMORE pGWS	PUG	SU	80	61	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash.
Mayo County Council	2200PRI2446	MOUNT JUBILEE pGWS	PUG	SU	171	25	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using chlorine gas. Flouridation also.
Mayo County Council	2200PRI2259	MOYRAHAN pGWS	PUG	SU	78	22	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Flouridation also.
Mayo County Council	2200PRI2364	NORTH COAST pGWS	PUG	SU	88	28	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using chlorine gas. Flouridation also.
Mayo County Council	2200PRI2373	POLLROHANAN pGWS	PUG	SU	35	0	No	Coagulation using polyaluminium chloride and poly LT25S. Chlorination using chlorine gas.
Mayo County Council	2200PRI2285	PULLATHOMAS pGWS	PUG	SU	381	61	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Flouridation also.
Mayo County Council	2200PRI2276	QUIGNAMANGER pGWS	PUG	SU	174	39	No	Coagulation using liquid alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Flouridation also.
Mayo County Council	2200PRI2227	RAHARD pGWS	PUG	SU	84	30	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash.
Mayo County Council	2200PRI2250	RATHCASH pGWS	PUG	SU	80	14	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash.
Mayo County Council	2200PRI2666	RATHFRAN pGWS	PUG	SU	57	10	No	Coagulation using liquid alum and poly Gokem a225, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Flouridation also.
Mayo County Council	2200PRI2141	ROSMONEY WEST PGW	PUG	GR	78	0	No	Coagulation using polyaluminium chloride and poly Clearfloc 903P, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Ph adjustment using chlorine gas.
Mayo County Council	2200PRI2361	ROSS pGWS (BALLINA)	PUG	SU	221	36	No	Coagulation using liquid alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Flouridation also.
Mayo County Council	2200PRI2202	SAULIA pGWS	PUG	SU	268	55	No	Coagulation using kibble alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Flouridation also.
Mayo County Council	2200PRI2036	SLIEVENAGARK pGWS	PUG	SU	50	20	No	Coagulation using liquid alum and poly LT25S, clarification, rapid gravity filtration followed by disinfection using chlorine gas. Flouridation also.
Mayo County Council	2200PRI2390	SRAH pGWS	PUG	SU	60	14	No	Coagulation using ferric sulphate and poly LT27, clarification, rapid gravity filtration followed by disinfection using chlorine gas and pH correction using soda ash.
Mayo County Council	2200PRI2153	SRAHEEN/AUGHAGOWI	PUG	SP	210	51	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction using soda ash.
Mayo County Council	2200PRI2366	TALLAGH HILL pGWS	PUG	SU	120	18	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using chlorine gas. Flouridation also.
Mayo County Council	2200PRI2177	TREENKEEL pGWS	PUG	SU	75	39	No	Coagulation using polyaluminium chloride and poly LT25S. Chlorination using chlorine gas.
Mayo County Council	2200PRI2367	TULLAGHANDUFF/BAWI	PUG	SU	93	32	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Flouridation also.
Mayo County Council	2200PRI2298	TULLAGHBAWN GWS	PUG	SU	86	30	No	Coagulation using liquid alum and poly 220P with pH adjustment using soda ash. Rapid gravity filtration and chlorination using sodium hypochlorite. Flouridation also.
Mayo County Council	2200PRI2540	SPS - ASHLEAGH LODG	PRI	SU	0	0	No	
Mayo County Council	2200PRI2783	SPS - Betty Rose Cupcak	PRI	SP	0	0	No	UV Treatment
Mayo County Council	2200PRI2400	SPS - BIOSHELL, CARRO	PRI	GR	0	0	No	UV Filtration
Mayo County Council	2200PRI2791	SPS - BREAFFY HOUSE	PRI	GR	0	0	No	
Mayo County Council	2200PRI2401	SPS - CAMPBELL'S BAR	PRI	SU	0	0	No	UV Filtration
Mayo County Council	2200PRI2665	SPS - CLAIRE HICKEY, F	PRI	GR	0	0	No	
Mayo County Council	2200PRI2677	SPS - CLARE ISLAND LI	PRI	SU	0	0	No	Filtration, Reverse Osmosis, UV
Mayo County Council	2200PRI2785	SPS - Cloona Health Retr	PRI	SP	0	0	No	
Mayo County Council	2200PRI2788	SPS - Croagh Patrick Holl	PRI	SU	30	10	No	
Mayo County Council	2200PRI2426	SPS - CROUGH PAT COI	PRI	SU	0	0	No	UV Filtration
Mayo County Council	2200PRI2403	SPS - CROUGH PATRICI	PRI	SU	0	0	No	UV Filtration and deionisation
Mayo County Council	2200PRI2405	SPS - DAVEY'S BAR, CAI	PRI	GR	0	0	No	UV Filtration
Mayo County Council	2200PRI2541	SPS - DELPHI LODGE	PRI	SU	0	0	No	
Mayo County Council	2200PRI2539	SPS - DELPHI MOUNTAIN	PRI	SU	0	0	No	O
Mayo County Council	2200PRI2550	SPS - DUFFYS GROCER	PRI	SU	0	0	No	UV Light Treatment
Mayo County Council	2200PRI2406	SPS - FLANAGAN'S BAR	PRI	GR	0	0	No	UV Filtration
Mayo County Council	2200PRI2407	SPS - GARVIN'S SUPERI	PRI	GR	0	0	No	None
Mayo County Council	2200PRI2545	SPS - GIBBONS FOODS'	PRI	GR	0	0	No	None
Mayo County Council	2200PRI2681	SPS - GLENKEEN FARM	PRI	GR	0	0	No	
Mayo County Council	2200PRI2410	SPS - HILLCREST HOME	PRI	GR	0	0	No	None
Mayo County Council	2200PRI2670	SPS - Lecarvey Commun	PRI	SU	40	8	No	UV
Mayo County Council	2200PRI2781	SPS - Mariko Green Tea	PRI	SP	0	0	No	
Mayo County Council	2200PRI2414	SPS - OLD HEAD BAR, L	PRI	GR	0	0	No	Ultra-violet Filtration
Mayo County Council	2200PRI2673	SPS - St John's Nursing H	PRI	GR	40	8	No	UV Light Treatment
Mayo County Council	2200PRI2416	SPS - STAUNTON'S BAR	PRI	SU	0	0	No	Ultra-violet Filtration and deionisation
Mayo County Council	2200PRI2555	SPS - THE LARCHES, FII	PRI	SU	0	0	No	UV Light Treatment
Mayo County Council	2200PRI2418	SPS - THE TAVERN BAR	PRI	SU	0	0	No	Ultra-violet Filtration and deionisation
Mayo County Council	2200PRI2451	SPS - TITHE COIS TRA, I	PRI	GR	0	0	No	None
Mayo County Council	2200PRI2546	SPS - WEST VIEW HOTE	PRI	GR	0	2	No	Filter and UV
Mayo County Council	2200PRI2790	SPS - Westport Plaza Hot	PRI	GR	30	10	No	
Mayo County Council	2200PRI2669	SPS St Attracta's Nursing	PRI	GR	40	8	No	UV
Mayo County Council	2200PRI2004	AILLE GWS (AYLE)	PRG	SU	195	80	No	Chlorination
Mayo County Council	2200PRI2003	ATTYMASS GWS	PRG	SP	871	340	No	Chlorination
Mayo County Council	2200PRI2006	BALLYCROY GWS	PRG	SU	1027	500	No	Pressure filter, membrane filtration & chlorination
Mayo County Council	2200PRI2011	BARNEYCARROLL GWS	PRG	GR	343	180	No	Chlorination
Mayo County Council	2200PRI2014	BELDERG GWS	PRG	SU	171	30	No	DBO contract - membrane filtration & chlorination
Mayo County Council	2200PRI2020	BRACKLOON/SPADDAG	PRG	SU	370	110	No	Rapid Gravity Filter, DAF, UV & Chlorination
Mayo County Council	2200PRI2557	CALLOW LAKE GWS	PRG	SU	3338	451	No	Pressure Sand Filter, unvalidated UV & Chlorination.
Mayo County Council	2200PRI2542	Clew Bay GWS	PRG	SU	1084	198	No	DAF with GAC for taste and odour, Unvalidated UV
Mayo County Council	2200PRI2339	CLOONLYON GWS	PRG	GR	50	20	No	Chlorination

Organisation Name	Scheme Code	Scheme Name	Supply Type	Source Type	Population Served	Volume Supplied	Derogation For Supply	Type Of Treatment
Mayo County Council	2200PRI2122	CLOONMORE/CLOONLA	PRG	SP	221	140	No	Chlorination & Unvalidated UV
Mayo County Council	2200PRI2121	CLOONMORE/ROOSKEY	PRG	SP	621	450	No	Adsorbntion Clarifier, chlorination and unvalidated UV
Mayo County Council	2200PRI2037	CREGGDUFF GWS	PRG	GR	673	546	No	Chlorination
Mayo County Council	2200PRI2326	CURRAMORE (BALLINR)	PRG	SU	257	136	No	Coagulation using ferric sulphate and poly Flopam 910, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite and pH correction U
Mayo County Council	2200PRI2035	CURRAUNBOY GWS (C)	PRG	SP	86	35	No	Ultra violet
Mayo County Council	2200PRI2043	CUSHIN GWS	PRG	SU	231	82	No	Chlorination
Mayo County Council	2200PRI2126	DERRYVOHY GWS	PRG	GR	301	132	No	Chlorine
Mayo County Council	2200PRI2125	DOOHOMA pGWS	PRG	GR	127	41	No	
Mayo County Council	2200PRI2047	DRUM / BINGHAMSTOW	PRG	SP	364	106	No	Sand Filter, Chlorine and unvalidated UV
Mayo County Council	2200PRI2127	DRUMMIN GWS	PRG	SU	148	89	No	Pressure Filter, Membrane Filtration, Chlorination
Mayo County Council	2200PRI2543	DRUMMINDOO FAHY GW	PRG	SU	1677	600	No	Rapid Gravity Filter, DAF, UV & Chlorination
Mayo County Council	2200PRI2128	DRUMSHEEN/NEWTOW	PRG	SP	78	31	No	Chlorination
Mayo County Council	2200PRI2130	ERREW GWS	PRG	SP	109	49	No	unvalidated UV
Mayo County Council	2200PRI2667	Farnaught pGWS	PRG	SU	70	0	No	Coagulation using polyaluminium chloride and poly Clearfloc 903P, clarification, rapid gravity filtration followed by disinfection using sodium hypochlorite. Ph adj
Mayo County Council	2200PRI2147	FUNSHINAUGH/CROSS	PRG	SU	421	455	No	Disc Filters, Chlorine and unvalidated UV
Mayo County Council	2200PRI2056	GLENCORRIB GWS	PRG	SU	1071	500	No	Pressure Filter, Membrane Filtration, Chlorination
Mayo County Council	2200PRI2057	GLENHEST GWS	PRG	SU	416	144	No	Pressure Filter, Membrane Filtration, Chlorination
Mayo County Council	2200PRI2064	IRISHTOWN GWS	PRG	GR	1006	371	No	Chlorination and unvalidated UV
Mayo County Council	2200PRI2065	JOHNSTOWN GWS	PRG	SP	476	184	No	Chlorination
Mayo County Council	2200PRI2159	KILCOLMAN/FACEFIELD	PRG	GR	380	160	No	Sand Filter, Chlorine and unvalidated UV
Mayo County Council	2200PRI2072	KILLASSER GWS	PRG	SP	1123	760	No	Pressure sand filter, Ozone and GAC, Chlorination & unvalidated UV
Mayo County Council	2200PRI2073	KILLATURLEY GWS	PRG	GR	933	546	No	Chlorination
Mayo County Council	2200PRI2074	KILLEEN GWS	PRG	SU	900	150	No	Nano Filtration Chlorination.
Mayo County Council	2200PRI2070	KILLGALLIGAN GWS	PRG	GR	73	24	No	None
Mayo County Council	2200PRI2075	KILMEENA GWS	PRG	SU	1079	267	No	Rapid Gravity Filter, DAF, UV & Chlorination
Mayo County Council	2200PRI2133	KILMOVEE/URLAUR GW	PRG	SU	1770	540	No	Rapid Gravity Filter, DAF, UV & Chlorination
Mayo County Council	2200PRI2079	LAGHTA GWS	PRG	SU	304	145	No	Pressure Filter, Membrane Filtration, Chlorination
Mayo County Council	2200PRI2668	Lough Carra GWS	PRG	SU	1502	0	No	Coagulation dosing, adsorption clarifer, pressure filtration, UV & Chlorination
Mayo County Council	2200PRI2083	LOUGH MASK CREEVAG	PRG	SU	970	300	No	Coagulation dosing, adsorption clarifier, pressure filtration, UV & Chlorination
Mayo County Council	2200PRI2136	LOUGHAUNNAMAN GW	PRG	GR	150	62	No	Chlorination & unvalidated UV
Mayo County Council	2200PRI2150	MIDFIELD GWS	PRG	GR	1097	300	No	Chlorination
Mayo County Council	2200PRI2551	MOYLAW GWS	PRG	GR	247	0	No	CHLORINATION
Mayo County Council	2200PRI2552	MOYLOUGH pGWS	PRG	SU	108	30	No	Filtration, Coagulation and Chlorination
Mayo County Council	2200PRI2549	NEPHIN VALLEY GWS	PRG	SU	1609	0	No	PRESSURE SAND FILTER, OZONE, GAC, CHLORINATION & UNVALIDATED UV
Mayo County Council	2200PRI2093	PARKE GWS	PRG	SU	956	391	No	Adsorbntion Clarifier, chlorination and unvalidated UV
Mayo County Council	2200PRI2559	PBKS GWS	PRG	SU	2056	700	No	Adsorbntion Clarifier, chlorination and unvalidated UV
Mayo County Council	2200PRI2137	POLLAVADDY pGWS	PRG	SP	154	100	No	
Mayo County Council	2200PRI2100	ROBEEEN GWS	PRG	SU	663	637	No	Chlorination
Mayo County Council	2200PRI2324	ROSSPORT GWS	PRG	SP	200	50	No	Chlorination
Mayo County Council	2200PRI2103	ROY BINGHAM'S GWS	PRG	SP	124	50	No	Chlorination and UV
Mayo County Council	2200PRI2105	SRAHEEN GWS (FOXFC)	PRG	SU	593	300	No	Pressure sand filter, Ozone and GAC, Chlorination & unvalidated UV(DBO2)
Mayo County Council	2200PRI2111	TOOREEN/AGHAMORE	PRG	SP	1020	450	No	Chlorination and UV
Mayo County Council	2200PRI2353	TREANNAGLERAGH GW	PRG	SP	52	25	No	None