

Organisation Name	Scheme Code	Scheme Name	Supply Type	Source Type	Population Served	Volume Supplied	Derogation For Supply	Type Of Treatment
Monaghan County Council	2400PUB1005	Carrickmacross	PWS	Mixture	4738	1239	No	Chlorination & Fluoridation
Monaghan County Council	2400PUB1002	Clones	PWS	Mixture	2695	907	No	Pre-treatment with Hypochlorite, Coagulation with Aluminium Sulphate and Polyelectrolyte Clearfloc 501p, Rapid Gravity Fil
Monaghan County Council	2400PUB1007	Drum	PWS	SU	41	7	No	see Drumgole GWS
Monaghan County Council	2400PUB1008	Emyvale	PWS	SU	767	149	No	see Glaslough Tyholland GWS
Monaghan County Council	2400PUB1004	Glaslough	PWS	SU	333	171	No	see Glaslough Tyholland GWS
Monaghan County Council	2400PUB1009	Inniskeen	PWS	SU	503	132	No	pH Adjustment with Sulphuric Acid, Coagulation with Ferric Chloride, Rapid Gravity Filtration, pH Correction with Sodium H
Monaghan County Council	2400PUB1001	LERWSS	PWS	SU	10369	4132	No	Coagulation with Aluminium Sulphate, Coagulation Aid is Polyelectrolyte Clearfloc 501p, Rapid Gravity Filtration, pH Correc
Monaghan County Council	2400PUB1024	Monaghan	PWS	Mixture	8812	2703	No	Pre-treatment with Potassium Permanganate, Rapid Gravity Filtration, pH Correction, Disinfection.
Monaghan County Council	2400PUB1003	Newbliss	PWS	SU	433	154	No	pH Adjustment with Sulphuric Acid, Coagulation with Ferric Chloride, Rapid Gravity Filtration, pH Adjustment with Sodium H
Monaghan County Council	2400PUB1010	Smithboro	PWS	GR	503	121	No	Chlorination
Monaghan County Council	2400PRI2011	Aughnashalvey	PRG	SU	1873	789	No	pH adjustment, Coagulation, Rapid Gravity Filtration, pH correction, disinfection.
Monaghan County Council	2400PRI2026	Barraghy Fermoyle	PRG	SU	49	9		
Monaghan County Council	2400PRI2020	Churchill/Oram	PRG	SU	1265	625	No	pH adjustment, Coagulation, Rapid Gravity Filtration, pH correction, disinfection.
Monaghan County Council	2400PRI2012	Corduff	PRG	SU	1581	523	No	pH adjustment, Coagulation, Rapid Gravity Filtration, pH correction, disinfection.
Monaghan County Council	2400PRI2013	Donaghmoynne	PRG	SU	4386	1770	No	Coagulation with PAC, Membrane Filtration, Disinfection with Sodium Hypochlorate.
Monaghan County Council	2400PRI2015	Doohamlet	PRG	SU	1045	428	No	pH adjustment, Coagulation, Rapid Gravity Filtration, pH correction, disinfection.
Monaghan County Council	2400PRI2016	Drumgole	PRG	SU	921	591	No	pH adjustment, Coagulation, Rapid Gravity Filtration, pH correction, disinfection.
Monaghan County Council	2400PRI2017	Glaslough/Tyholland	PRG	SU	2164	927	No	Coagulation, Rapid Gravity Filtration, Activated Carbon addition (when necessary), pH Correction, Disinfection.
Monaghan County Council	2400PRI2018	Killanny	PRG	SU	2585	1516	No	pH adjustment, Coagulation, Rapid Gravity Filtration, pH correction, Disinfection.
Monaghan County Council	2400PRI2019	Magheraclone	PRG	SU	2415	1203	No	Slow Sand Filtration followed by disinfection with Sodium Hypochlorate.
Monaghan County Council	2400PRI2021	Stranoodan	PRG	SU	3127	1745	No	Coagulation, Rapid Gravity Filtration, pH Correction, Disinfection.
Monaghan County Council	2400PRI2022	Truagh	PRG	SU	2390	969	No	pH adjustment, Coagulation, Rapid Gravity Filtration, pH correction, Disinfection.
Monaghan County Council	2400PRI2023	Tydavnet	PRG	GR	2811	1168	No	Alkalinity buffering, Coagulation, Rapid Gravity Filtration, pH correction, Disinfection.